



Bhatnagar International School

Sector - B, Pocket - X, Vasant Kunj, New Delhi - 110070

Ph: 26893497, 26891277

School ID: 1720145

CBSE Affiliation Number : 2730193

Ref. No. BIS(V-X) 4338

Dated: 26/05/2025

To,
Delhi Jal Board
Govt of NCT of Delhi
RWS Quality Control Division,
Bottling Plant, GK-1
New Delhi-110048

Dear Sir,

This is to request you to send an officer for inspection of the drinking water in our school. The DJB water connection number of our school is Delhi Jal Board K No. 1606811000. Details of the Water Point as below: -

- | | | |
|--------------------------|-----------|---------------------------|
| 1. Main Gate | : - No. 1 | Use by Driver & Conductor |
| 2. Ground Floor | : - No. 1 | Use d by IV Class |
| 3. Ist Floor | : - No. 2 | Use d by IV Class |
| 4. 2 nd Floor | : - No. 1 | Use d by IV Class |
| 5. 3 rd Floor | : - No. 2 | Use d by IV Class |

Total Number of R.O. 7

Kindly get it done at the earliest and issue the Quality Water Certificate for our organization.

Thanks, and Regards

Shilpa Bhatnagar
(PRINCIPAL)
Bhatnagar International School
Sector - B, Pocket - X, Vasant Kunj,
New Delhi - 110070

(1) Inlet
(7) Outlet

Enclosure: -

1. Delhi Jal Board Bill Copy
2. Delhi Jal Board Payment slip Copy
3. Delhi Jal Board Water Certificate

Challan issued for 8 nos.
of Inlets 1 Inlet DJB and
7 outlets (Ro of the building)
A/c. No. R 6560

Received by
Tarek
Blanchel
Asst. Secy
27/5/25

ACWA GK

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

 Delhi Jal Board	OFFICE OF THE ACWA (RWS & BOTTLING PLANT) DELHI JAL BOARD QUALITY CONTROL DIVISION BOTTLING PLANT, GREATER KAILASH, NEW DELHI-110048	 Bureau of Indian Standards IS / ISO 9001 Licence No- CRO/QM/L-8004282, IS/ISO 9001:2015

Ref No:- DJB/QCL-RWS/GK-I/FLE-08/FRM-08/01

Dated: 04.04.2024



Analysis Report of Water sample collected from:- M/S Bhatnagar International School, Sector-B, Pocket-X, Vasant Kunj, New Delhi- 110070.


Vide Challan No-2, Dated: - 26.03.2024

1. Main supply near entry gate
2. After R/O near 1-B Ground floor
3. After R/O near V-B 1st Floor
4. After R/O Inside chemistry lab, 1st Floor

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		Result			
			Acceptable	Permissible				
					1.	2.	3.	4.
1.	Date of collection	----	----	----	01.04.2024	01.04.2024	01.04.2024	01.04.2024
2.	Date of Analysis	----	----	----	01.04.2024	01.04.2024	01.04.2024	01.04.2024
3.	Color	Hazen	5	15	Clear	Clear	Clear	Clear
4.	Odour	----	Non - Objectionable		Agreeable	Agreeable	Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	3.14	0.96	1.16	1.39
6.	pH value	----	6.5-8.5	N.R.	7.66	7.71	7.71	7.65
7.	Electrical Conductivity	µS/cm	----	----	178.3	182.5	180	177.8
8.	Total Dissolved Solid	(mg/L)	500	2000	115.9	118.6	117	115.6
9.	Phenolphthalein Alkalinity	(mg/L)	----	----	NIL	NIL	NIL	NIL
10.	Total Alkalinity (as CaCO ₃)	(mg/L)	200	600	66	82	66	70
11.	Total Hardness (as CaCO ₃)	(mg/L)	200	600	108	96	112	107
12.	Calcium Hardness	(mg/L)	----	----	58	64	62	62
13.	Magnesium Hardness	(mg/L)	----	----	50	32	50	40
14.	Calcium as 'Ca'	(mg/L)	75	200	23.2	25.6	24.8	24.8
15.	Magnesium as 'mg'	(mg/L)	30	100	12	7.68	12	9.6
16.	Ammonia (NH ₃ -N)	(mg/L)	0.5	N.R.	ND	ND	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/L)	----	----	ND	ND	ND	ND
18.	Nitrate (NO ₃ -)	(mg/L)	45	N.R.	1.50	1.41	1.38	1.82
19.	Sulphate	(mg/L)	200	400	20.43	13.29	11.21	17.91
20.	Chloride (Cl)	(mg/L)	250	1000	20	22	22	24
21.	Iron (Fe)	(mg/L)	0.3	N.R.	0.01	0.02	0.01	0.01
22.	Fluoride	(mg/L)	1.0	1.5	0.38	0.30	0.34	0.39
23.	Residual Chlorine	(mg/L)	0.2	1.0	1.25	ND	0.40	1.0

Remarks –On the basis of above parameters tested, the collected water samples 1, 2, 3 & 4 conform to the drinking water specification IS-10500-2012.


A.C.W.A
T. N. RAI
 ACWA (RWS & BP)
 Delhi Jal Board
 Govt. of NCT of Delhi

Principal
 Bhatnagar International School
 Vasant Kunj,
 New Delhi-110 070


Chemist


Asst. Chemist


MANAGER
 Bhatnagar International School
 Sector-B Vasant Kunj
 New Delhi-110070

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

 Delhi Jal Board	OFFICE OF THE ACWA (RWS & BOTTLING PLANT) DELHI JAL BOARD QUALITY CONTROL DIVISION BOTTLING PLANT, GREATER KAILASH, NEW DELHI-110048	 LICENCE No- CRO/QM/L-8004282, IS/ISO 9001:2015

Ref No.:- DJB/QCL-RWS/GK-I/FLE-08/FRM-08/01

Dated: 04.04.2024


Analysis Report of Water sample collected from:- M/S Bhatnagar International School, Sector-B, Pocket-X, Vasant Kunj, New Delhi-110070


Vide Challan No- 2, Dated: - 26.03.2024


5. After R/O near VII-C, IInd floor
6. After R/O near X-B, IIIrd floor
7. After R/O near Math Lab


S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		Result		
			Acceptable	Permissible			
					5.	6.	7.
24.	Date of collection	----	----	----	01.04.2024	01.04.2024	01.04.2024
25.	Date of Analysis	----	----	----	01.04.2024	01.04.2024	01.04.2024
26.	Color	Hazen	5	15	Clear	Clear	Clear
27.	Odour	----	Non - Objectionable		Agreeable	Agreeable	Agreeable
28.	Turbidity	N.T.U	1.0	5.0	2.07	3.50	1.34
29.	pH value	----	6.5-8.5	N.R.	7.61	7.64	7.73
30.	Electrical Conductivity	µS/cm	----	----	184.6	176.6	144.8
31.	Total Dissolved Solid	(mg/L)	500	2000	119.9	114.8	94.1
32.	Phenolphthalein Alkalinity	(mg/L)	----	----	NIL	NIL	NIL
33.	Total Alkalinity (as CaCO ₃)	(mg/L)	200	600	68	62	64
34.	Total Hardness (as CaCO ₃)	(mg/L)	200	600	118	108	116
35.	Calcium Hardness	(mg/L)	----	----	66	64	56
36.	Magnesium Hardness	(mg/L)	----	----	52	44	60
37.	Calcium as 'Ca'	(mg/L)	75	200	26.4	25.6	22.4
38.	Magnesium as 'mg'	(mg/L)	30	100	12.48	10.56	14.4
39.	Ammonia (NH ₃ -N)	(mg/L)	0.5	N.R.	ND	ND	ND
40.	Nitrite -Nitrogen (N)	(mg/L)	----	----	ND	ND	ND
41.	Nitrate (NO ₃ -)	(mg/L)	45	N.R.	1.53	1.43	1.28
42.	Sulphate	(mg/L)	200	400	23.28	22.79	15.21
43.	Chloride (Cl ⁻)	(mg/L)	250	1000	22	20	16
44.	Iron (Fe)	(mg/L)	0.3	N.R.	0.02	0.01	0.01
45.	Fluoride	(mg/L)	1.0	1.5	0.16	0.10	0.34
46.	Residual Chlorine	(mg/L)	0.2	1.0	0.25	ND	0.50

Remarks –On the basis of above parameters tested, the collected water samples 5, 6 & 7 Conform to the drinking water specification IS-10500-2012.


A.C.W.A. N. RAI
 ACWA (RWS & BP)
 Delhi Jal Board
 Govt. of NCT of Delhi


Chemist


Asst. Chemist


Principal
 Bhatnagar International School
 Vasant Kunj,
 New Delhi-110 070


MANAGER
 Bhatnagar International School
 Sector-B, Pocket-X, Vasant Kunj

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

 Delhi Jal Board	OFFICE OF THE ACWA (RWS & BOTTLING PLANT) DELHI JAL BOARD QUALITY CONTROL DIVISION BOTTLING PLANT, GREATER KAILASH, NEW DELHI-110048	 आज़ादी का अमृत महोत्सव
	 Licence No- CRO/QM/L-8004282, IS/ISO 9001:2015	

Date:-03/04/2024

Bacteriological Analysis Report

Ref:- DJB/QCL-RWS/GK-I/FLE-08/FRM-01/01

To,
M/s Bhatnagar International School,
Sector-B, Pocket-X, Vasant kunj,
New Delhi-110070


Party's ref. & Date - BTS/V.K/3815 & 13/03/2024
 Dept. Challan No. & Date - 02 & 23/03/2024
 Date of sample collection - 01/04/2024
 No. of sample(s) - SEVEN (07)
 Reported on - 03/04/2024

Note: Coliform count at 37°C/100 ml after 48 Hrs.

S. No. as in record	Particulars	Clarity	R/Cl ₂ mg/L	Coliform MPN/ 100 ml
P1	Main supply near entry gate	Clear	1.25	0
P2	After RO near Class I-B Ground floor	Clear	ND	0
P3	After RO near Class V-B First floor	Clear	0.4	0
P4	After RO near inside Chemistry Lab First floor	Clear	1.0	0
P5	After RO near Class VII-C Second floor	Clear	0.25	0
P6	After RO near Class X-B Third floor	Clear	ND	0
P7	After RO near Maths Lab	Clear	0.5	0


R/Cl₂= Residual Free Chlorine

Remarks: - The above collected water samples found satisfactory in bacteriological examination.



ACWA (RWS & BP)
Delhi Jal Board
Govt. of NCT of Delhi
Principal
Bhatnagar International School
Vasant Kunj,
New Delhi-110 070

Bacteriologist (RWS)


Lab. /Tech.


Bhatnagar International School
Sector-B, Pocket-X, Vasant Kunj,
MANAGER



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT : SOUTH ZONE
GREEN PARK, AUROBINDO MARG NEW DELHI 110016

No: DHO/SZ/2023/ D 773

Dated ...22/6/23

SCHOOL HEALTH CERTIFICATE

1. Name of the School... Bhatnagar International School
2. School Address... Sector-B, Pocket-X, Vasant Kunj, New Delhi-110070
3. No. of Shift... One Timing... Morning
4. No. of Students: Boys... 1013 Girls... 616 Total... 1629
5. No. of Staffs: Male... 12 Female... 62 Total... 74

Details of Accommodations present in School

1. Floor Space in the Classroom Sufficient/insufficient... Sufficient
2. The Classrooms are Well Lighted/ ill lighted... Well Lighted
3. The Classrooms are Well Ventilated/ ill ventilated... Well Ventilated
4. The Classrooms are kept / Not kept Neat & Clean: ... Neat & Clean
5. The Classrooms/Building requires/ do not required Whitewash etc. ... Not required
6. The Drinking Water is Wholesome/ not wholesome ... Wholesome
7. The Latrine arrangement is Sanitary/ insanitary... Sanitary

No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is ... Sufficient
2. One latrine for 40 male student is required so total is ... Sufficient
3. Separate Toilet arrangement for staff present: Yes/No... Yes
4. The Overall facilities: Good/ Adequate/Inadequate ... Good from health point of view and valid upto one year from issuance date

If Building Department or any other Govt. agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/revoked without any further intimation in this regard.

Shilpa Bhatnagar
Bhatnagar International School (Recog.)
Sector-B, Pocket-X

Dr. Deepak Mittal
Deputy Health Officer
South Zone
Uy. Health Officer/SZ



OFFICE OF DY HEALTH OFFICER
SOUTH ZONE GREEN PARK, NEW DELHI-110016
dhosouthzone@gmail.com

No.DHO/SZ/MCD/2024/ 2823

Date 25/7/2024

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Hemant Kumar (Assistant Public Health Inspector) from the Public Health Department, South Zone inspected the Bhatnagar International School situated at Sector-B, Pocket-X, Vasant Kunj, New Delhi-110070 on 16/07/2024 and found that the Bhatnagar International School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from the date of issue.

Dy. Health Officer

South Zone
Dy. Health Officer
South Zone MCD

Copy to:-

1. The Principal, Bhatnagar International School
Sector-B, Pocket-X, Vasant Kunj, New Delhi-110070
2. Office copy

Sh. P. Bhatnagar

Bhatnagar International School (Recog.)
Sector-B, Pocket-X
Vasant Kunj, New Delhi-110070